

Access Statement

Strathclyde County Park Caravan Club Site



Arrival and Car Parking Facilities

New arrivals bays are located next to reception. At the site entrance there are 5 visitor car parking bays including 1 accessible car parking bay. The late arrivals area provides space for 2 caravans with electric hook up points. There is a level access route from arrival and parking areas to reception. The main site areas are access controlled by barrier, controls are mounted at a height of 1200mm.

Reception

The reception is accessed from a level pathway. The reception door achieves an 800mm clear opening width over a level threshold. The call bell is mounted at a height of 1500mm above floor level. Internally the reception area achieves adequate wheelchair manoeuvring and turning space. The reception counter incorporates a low level position suitable for most users with a clear 720mm knee recess. The reception is not fitted with a hearing induction loop system to assist hearing aid users.

Pitches

The site has a total of 107 pitches, all pitches have a hard standing. There are 12 fully serviced pitches with drainage and water supplies. There are no pitches permanently designated for disabled people. There are 13 pitches located on a level section of the site within 35m of Toilet Block 1. There are 5 pitches located on a level section of the site within 35m from Toilet Block 2. The site has 2 camping fields providing a total of 45 tent pitches located adjacent to Toilet Block 2. The site has 2 camping pods located adjacent to Toilet Block 2.

Circulation around the Site

The site is reasonably level. There are a small number of pedestrian footpaths. Most of the access roads around the site are shared by vehicles and pedestrians. The principal access road linking the car park, reception and Toilet Block 2 has a separate footpath.

Toilet Blocks

The larger Toilet Block 1 is located centrally. Toilet Block 2 is located to the northwest of the site near the camping fields. Level access pathways are provided around the perimeter of each. Toilet Block 1 has a parking area for 4 vehicles.

Toilet block 1 **accessible WC and shower door** achieves an opening width of 800mm over a level threshold. The door is operated by a RADAR key available from Reception. The cubicle size is 2750 x 2600mm. The level access shower is designed for left hand transfer. The WC is designed for right hand transfer. The WC basin and shower have ergonomic lever style controls and are fitted with contrasted grab rails. The cubicle is fitted with an alarm system. The basin sits within a 360mm recess, making it difficult for some users to reach from the WC pan. Toilet Block 2 does not have an **accessible toilet and shower cubicle**.



Within Toilet Blocks 1 and 2 **male and female toilet** doors achieve an 800mm clear opening width over a level threshold. Ambulant disabled WC and shower cubicles are provided with contrasting grab rails. Showers are level access with a recessed drainage gully. WC's, basins and showers have ergonomic lever style controls.

Other Facilities

Within Toilet Block 1 the **laundry** door achieves an 800mm clear opening width over a level threshold. Circulation space within the Laundry narrows to as little as 1100mm between the washers, dryers and sink counter. The room does not achieve adequate wheelchair manoeuvring and turning space. Washers and dryers are coin operated and front loading. Counter mounted sinks are fitted with ergonomic lever style taps. Counters are set at a height of 880mm with 770mm knee space. Toilet Block 2 does not have a **laundry** facility.

Within Toilet Block 1 the **baby and toddler room** door achieves a clear opening width of 800mm over a level threshold. The room size is 2400 x 2700mm and achieves adequate wheelchair manoeuvring and turning space. Facilities include a lowered toddlers WC, wash hand basin, small bath with shower over and wall mounted baby changing unit at a height of 800mm. The basin is fitted with an ergonomic lever style tap and the bath mixer is fitted with thumb turn taps. Toilet Block 2 does not have a **baby and toddler room**.

Toilet Block 1 **dishwashing area** door achieves a width of 800mm over a level threshold. Internally the room achieves adequate wheelchair manoeuvring and turning space with a 2000mm gap between sink counters. Counter mounted sinks are fitted with ergonomic lever style taps, counters are mounted at 880mm, achieving 770mm knee space. Toilet Block 2 has a covered **dishwashing area** which is open sided. Counter mounted sinks are fitted with ergonomic lever style taps, sinks are mounted at a height of 920mm with clear 820mm knee space.

Service points are provided at regular intervals around the site as well as at Toilet Blocks. Service points provide drinking water, waste water, chemical waste points, general waste disposal and recycling bins. Circulation space around service points narrows to as little as 750mm at some points. The site also has a motorhome waste point.

A **children's playground** is located close to Toilet Block 2 accessed from a tarmac pedestrian pathway with a crossing point. The gated access achieves a width exceeding 1m. The children's play equipment is mounted on safety flooring.

2 **camping pods** are located to the rear of Toilet Block 2 adjacent to the camping fields. Internally pods achieve an approximate overall size of 3400mm x 2200mm. Facilities consist of 2 camping beds, 2 chairs and a central table. Pods are not served by a formal pathway and are raised above ground level accessed via a flight of 4 steps with handrails to either side.

A **dog walk pathway** is provided to the north west of the site. The dog walk is accessed via a gravelled pathway which subsequently links to a loose laid bark covered pathway through a wooded area.

To the north of the site is a large **storage compound**. This facility is access controlled by a barrier. The proximity card reader is post mounted at a height of 1100mm. Access roads around the compound consist of gravel laid over a compacted sub-base. The storage compound is served by a car parking area which includes 2 accessible car parking spaces.

The **information room** is located adjacent to reception. The door achieves a 690mm clear opening over a level threshold. The room size is 2800 x 1800mm, achieving adequate wheelchair manoeuvring and turning space. Information leaflets are displayed in the range of 500-1300mm above floor level.